

Tel: 58154273, 58154274  
Fax: 880-2-9141234  
E-mail: wqtl@ngof.org  
Website: www.ngof.org

# Water Quality Testing Laboratory



Drink Safe Water Save Life

## Chemical/Bacteriological/Physical Analysis of Water Samples

WQTL Code: Y-104

Ref.: WQTL/209 - 265/21

Date: 23-Jun-21

Sample Code: Y104-1/3

Date of Sample Receiving: 16-Jun-21

Sample(s) Sent By: Shujola, H2O - Swiss Contact Bangladesh

## General Information of Samples:

Technology/Sample Source: **Supply Water**

Tested parameters: Arsenic, Iron, Manganese, Hardness, Chloride, Turbidity, TDS, pH, TC, FC & E.coli

Village: -

Union: -

Upazila: **Gazipur City**


District: **Gazipur**


Location of Water Point: **Gazipur City**

## TEST RESULTS

Name of Parameters	Concentration Present	Drinking Water Quality Standard (ECR '97 - Bangladesh)	Unit
Arsenic	<0.003	0.05	mg/L
Iron	<0.05	1.0	mg/L
Manganese	<0.1	0.1	mg/L
Hardness	8	-	mg/L
Chloride	<60	150 - 600	mg/L
Turbidity	<1	10	NTU
TDS	160	1,000	mg/L
pH	7.3	6.5 - 8.5	-
TC	18	0	#/100ml
FC	4	0	#/100ml
E.coli	0	0	#/100ml

Report Prepared & Checked by -

  
Md. Ibrahim Khalil  
Sr. Chemist

  
S. M. Shahidullah  
Manager